ALL-LITE

EAJ-637

Acoustical Louver
6" deep • 37° Insulated J-blade

The EAJ-637 extruded aluminum acoustical louver incorporates a J-blade and is designed for intake and exhaust applications where space is limited. The EAJ-637 is available in a wide array of finishes including custom color matching.

Standard Construction

Material: Mill finish 6063-T5 extruded aluminum **Frame:** 6" deep \times 0.081" thick (152 \times 2) channel

Blades: $37^{\circ} \times 0.081$ " (2) thick J-style with a 26 ga. (0.55)

thick perforated backing packed with non-combustible

insulating material

Screen: $1/2" \times 0.063" (12.7 \times 1.6)$ expanded and

flattened aluminum

Minimum Size: $12" \times 12" (305 \times 305)$

Maximum Size:

Single section: $60" \times 120" (1524 \times 3048)$

Multiple section: Unlimited

Options

■ Factory finish:

High Performance Fluoropolymer

Baked Enamel
 Prime Coat

Clear Anodize
 Integral Color Anodize

■ Frame Options:

• 1-1/2" (38) flange frame

Stucco flange
 Glazing frame

■ Installation Hardware

Clip anglesContinuous angles

■ Alternate bird or insect screens

■ Insulated or non-insulated blank-off panels

■ Filter racks

■ Hinged frame


■ Subframe

■ Head and/or sill flashing

■ Burglar bars

■ Frame closure

■ Net OD (actual size)



Ratings

Free Area: $[48" \times 48" (1219 \times 1219) \text{ unit}]: 5.2 \text{ ft}^2 (0.48 \text{ m}^2)$

32.5%

Performance @ Beginning Point of Water Penetration

Free Area Velocity: 890 fpm (4.52 m/s)

Air Volume Delivered: 4,627 cfm (2.18 m³/s)

Pressure Loss: 0.15 in.wg. (37 Pa)

Velocity @ 0.15 in.wg. Pressure Loss: 890 fpm (4.52 m/s)

Design Load: 30 psf

Acoustical Performance:

| Octave Band | 2 | 3 | 4 | 5 | 6 | 7 |
|-------------------|-----|-----|-----|------|------|------|
| Center Freq. (hz) | 125 | 250 | 500 | 1000 | 2000 | 4000 |
| Transmission Loss | 2 | 2 | 4 | 8 | 9 | 7 |
| Noise Reduction | 10 | 10 | 12 | 22 | 20 | 19 |

NOTE: Dimensions in parentheses () are millimeters. Information is subject to change without notice or obligation.

Free Area (ft²)


Width (Inches)

| | 12 | 18 | 24 | 30 | 36 | 42 | 48 | 54 | 60 |
|-----|-----|-----|-----|-----|------|------|------|------|------|
| 12 | 0.2 | 0.3 | 0.4 | 0.5 | 0.5 | 0.6 | 0.7 | 0.8 | 0.9 |
| 18 | 0.3 | 0.5 | 0.7 | 0.9 | 1.1 | 1.3 | 1.5 | 1.7 | 1.9 |
| 24 | 0.5 | 0.8 | 1.1 | 1.4 | 1.6 | 1.9 | 2.2 | 2.5 | 2.8 |
| 30 | 0.6 | 1.0 | 1.4 | 1.8 | 2.2 | 2.6 | 3.0 | 3.4 | 3.7 |
| 36 | 0.8 | 1.3 | 1.8 | 2.3 | 2.7 | 3.2 | 3.7 | 4.2 | 4.7 |
| 42 | 1.0 | 1.5 | 2.1 | 2.7 | 3.3 | 3.9 | 4.5 | 5.0 | 5.6 |
| 48 | 1.1 | 1.8 | 2.5 | 3.2 | 3.8 | 4.5 | 5.2 | 5.9 | 6.6 |
| 54 | 1.3 | 2.1 | 2.8 | 3.6 | 4.4 | 5.2 | 5.9 | 6.7 | 7.5 |
| 60 | 1.5 | 2.3 | 3.2 | 4.1 | 4.9 | 5.8 | 6.7 | 7.6 | 8.4 |
| 66 | 1.6 | 2.6 | 3.6 | 4.5 | 5.5 | 6.5 | 7.4 | 8.4 | 9.4 |
| 72 | 1.8 | 2.8 | 3.9 | 5.0 | 6.0 | 7.1 | 8.2 | 9.2 | 10.3 |
| 78 | 1.9 | 3.1 | 4.3 | 5.4 | 6.6 | 7.8 | 8.9 | 10.1 | 11.2 |
| 84 | 2.1 | 3.4 | 4.6 | 5.9 | 7.1 | 8.4 | 9.7 | 10.9 | 12.2 |
| 90 | 2.3 | 3.6 | 5.0 | 6.3 | 7.7 | 9.1 | 10.4 | 11.8 | 13.1 |
| 96 | 2.4 | 3.9 | 5.3 | 6.8 | 8.2 | 9.7 | 11.2 | 12.6 | 14.1 |
| 102 | 2.6 | 4.1 | 5.7 | 7.2 | 8.8 | 10.3 | 11.9 | 13.5 | 15.0 |
| 108 | 2.7 | 4.4 | 6.0 | 7.7 | 9.3 | 11.0 | 12.6 | 14.3 | 15.9 |
| 114 | 2.9 | 4.7 | 6.4 | 8.2 | 9.9 | 11.6 | 13.4 | 15.1 | 16.9 |
| 120 | 3.1 | 4.9 | 6.8 | 8.6 | 10.4 | 12.3 | 14.1 | 16.0 | 17.8 |


Water Penetration

AMCA defines the beginning point of water penetration as the free area velocity at the intersection of a simple linear regression of test data and the line of 0.01 ounces of water per square foot of free area measured through a 48" x 48" louver during a 15 minute period. The AMCA water penetration test provides a method for comparing louver models and designs as to their efficiency in resisting the penetration of rainfall under specific lab conditions. We recommend that intake louvers are selected with a reasonable margin of safety below the beginning point of water penetration in order to avoid unwanted penetration during severe storm conditions.

Beginning Point of Water Penetration = 890 fpm



Pressure Loss



Louver Test Size = 48" x 48" (1219 x 1219)


Pressure loss tested in accordance with Figure 5.5 of AMCA

Standard 500-L. Data corrected to standard air density.


EAJ-637

Acoustical Louver 6" deep • 37° Insulated J-blade

Attributes



Supplemental Options



Hinge and Subframe

Right or Left Side Option Available

Louver

Stucco Flange

Flashing Options

Head and Sill Available

Sill Flashing