

Application

The EFY-245 extruded aluminum louver is designed for intake and exhaust application where protection against water infiltration is not critical. The EFY-245 is well suited for special shape applications and is available with hidden mullions for a continuous blade appearance of multiple section assemblies. The EFY-245 is available in a wide array of anodized and painted finishes including custom color matching.

Standard Construction

Material: Mill finish 6063-T5 extruded aluminum.

Frame: 2" deep \times 0.060" thick (51 \times 1.5) channel.

Blades: $45^{\circ} \times 0.060^{"}$ (1.5) thick inverted Y-style.

Mullion: Visible.

Minimum Size: 4.5" × 4.5" (114 × 114)

Options

□ Factory finish:

- □ High Performance Fluoropolymer 100% resin Newlar[®]/ 70% resin Kynar[®]
- Baked Enamel
- Clear or Color Anodized, Class 1
- Prime Coat
- ☐ Hidden vertical mullion for continuous blade appearance.
- □ Flange Frame:
 - □ 11/2" (38) flange frame
 - Custom-sized flange
 - □ Stucco flange
 - Glazing frame
- Installation hardware:
 Clip angles
 Continuous angles
- Burglar Bars:

□ Shipped loose □ Shipped mounted

- □ Frame closure.
- U Welded construction.
- □ Alternate bird or insect screens.
- □ Insulated or non-insulated blank-off panels.
- □ Filter racks.
- □ Hinged frame.
- □ Head and/or sill flashing.




Free Area: [48" \times 48" (1219 \times 1219) unit]: 4.9 ft² (0.46 m²) 30.8%

Performance @ Beginning Point of Water Penetration Free Area Velocity: 679 fpm (3.45 m/s)


 Air Volume Delivered:
 3,351 cfm (1.58 m³/s)

 Pressure Loss:
 0.34 in.wg. (86 Pa)




Stiffener and Blade Brace

Model **EFY-245** (standard) *Louver dimensions furnished approximately 1/2" (13) undersize. Vertical Section *Screen adds approximately 3/16" (5) to louver depth.



Visible Vertical Mullion (standard)



Hidden Vertical Mullion



Horizontal Mullion (standard)



Flange Frame (optional)


Please contact the factory for any specific wind-loading requirements. Information is subject to change without notice or obligation.

Performance Data

Free Area (ft²)

| | | | | | | | | | | Width (In | ches) | | | | | | | | | |
|-----------------|-----|-----|-----|-----|-----|-----|------|------|------|-----------|-------|------|------|------|------|------|------|------|------|------|
| | | 12 | 18 | 24 | 30 | 36 | 42 | 48 | 54 | 60 | 66 | 72 | 78 | 84 | 90 | 96 | 102 | 108 | 114 | 120 |
| Height (Inches) | 12 | 0.2 | 0.3 | 0.4 | 0.5 | 0.6 | 0.7 | 0.8 | 0.9 | 1.0 | 1.1 | 1.2 | 1.3 | 1.4 | 1.5 | 1.6 | 1.7 | 1.8 | 1.8 | 1.9 |
| | 18 | 0.3 | 0.5 | 0.7 | 0.9 | 1.1 | 1.3 | 1.5 | 1.6 | 1.8 | 2.0 | 2.2 | 2.4 | 2.6 | 2.8 | 3.0 | 3.2 | 3.3 | 3.5 | 3.7 |
| | 24 | 0.5 | 0.8 | 1.0 | 1.3 | 1.6 | 1.9 | 2.2 | 2.4 | 2.7 | 3.0 | 3.3 | 3.5 | 3.8 | 4.1 | 4.4 | 4.7 | 4.9 | 5.2 | 5.5 |
| | 30 | 0.6 | 1.0 | 1.4 | 1.7 | 2.1 | 2.5 | 2.8 | 3.2 | 3.6 | 4.0 | 4.3 | 4.7 | 5.1 | 5.4 | 5.8 | 6.2 | 6.5 | 6.9 | 7.3 |
| | 36 | 0.8 | 1.3 | 1.7 | 2.2 | 2.6 | 3.1 | 3.5 | 4.0 | 4.5 | 4.9 | 5.4 | 5.8 | 6.3 | 6.7 | 7.2 | 7.7 | 8.1 | 8.6 | 9.0 |
| | 42 | 1.0 | 1.5 | 2.1 | 2.6 | 3.1 | 3.7 | 4.2 | 4.8 | 5.3 | 5.9 | 6.4 | 7.0 | 7.5 | 8.1 | 8.6 | 9.2 | 9.7 | 10.3 | 10.8 |
| | 48 | 1.1 | 1.8 | 2.4 | 3.0 | 3.7 | 4.3 | 4.9 | 5.6 | 6.2 | 6.8 | 7.5 | 8.1 | 8.8 | 9.4 | 10.0 | 10.7 | 11.3 | 11.9 | 12.6 |
| | 54 | 1.3 | 2.0 | 2.7 | 3.4 | 4.2 | 4.9 | 5.6 | 6.4 | 7.1 | 7.8 | 8.5 | 9.3 | 10.0 | 10.7 | 11.4 | 12.2 | 12.9 | 13.6 | 14.3 |
| | 60 | 1.4 | 2.2 | 3.1 | 3.9 | 4.7 | 5.5 | 6.3 | 7.1 | 8.0 | 8.8 | 9.6 | 10.4 | 11.2 | 12.0 | 12.8 | 13.7 | 14.5 | 15.3 | 16.1 |
| | 66 | 1.6 | 2.5 | 3.4 | 4.3 | 5.2 | 6.1 | 7.0 | 7.9 | 8.8 | 9.7 | 10.6 | 11.5 | 12.4 | 13.4 | 14.3 | 15.2 | 16.1 | 17.0 | 17.9 |
| | 72 | 1.7 | 2.7 | 3.7 | 4.7 | 5.7 | 6.7 | 7.7 | 8.7 | 9.7 | 10.7 | 11.7 | 12.7 | 13.7 | 14.7 | 15.7 | 16.7 | 17.7 | 18.7 | 19.6 |
| | 78 | 1.9 | 3.0 | 4.1 | 5.2 | 6.2 | 7.3 | 8.4 | 9.5 | 10.6 | 11.7 | 12.7 | 13.8 | 14.9 | 16.0 | 17.1 | 18.2 | 19.2 | 20.3 | 21.4 |
| | 84 | 2.1 | 3.2 | 4.4 | 5.6 | 6.8 | 7.9 | 9.1 | 10.3 | 11.4 | 12.6 | 13.8 | 15.0 | 16.1 | 17.3 | 18.5 | 19.7 | 20.8 | 22.0 | 23.2 |
| | 90 | 2.2 | 3.5 | 4.7 | 6.0 | 7.3 | 8.5 | 9.8 | 11.1 | 12.3 | 13.6 | 14.8 | 16.1 | 17.4 | 18.6 | 19.9 | 21.2 | 22.4 | 23.7 | 25.0 |
| | 96 | 2.4 | 3.7 | 5.1 | 6.4 | 7.8 | 9.1 | 10.5 | 11.8 | 13.2 | 14.5 | 15.9 | 17.3 | 18.6 | 20.0 | 21.3 | 22.7 | 24.0 | 25.4 | 26.7 |
| | 102 | 2.5 | 4.0 | 5.4 | 6.9 | 8.3 | 9.7 | 11.2 | 12.6 | 14.1 | 15.5 | 17.0 | 18.4 | 19.8 | 21.3 | 22.7 | 24.2 | 25.6 | 27.1 | 28.5 |
| | 108 | 2.7 | 4.2 | 5.7 | 7.3 | 8.8 | 10.3 | 11.9 | 13.4 | 14.9 | 16.5 | 18.0 | 19.5 | 21.1 | 22.6 | 24.1 | 25.7 | 27.2 | 28.7 | 30.3 |
| | 114 | 2.8 | 4.5 | 6.1 | 7.7 | 9.3 | 11.0 | 12.6 | 14.2 | 15.8 | 17.4 | 19.1 | 20.7 | 22.3 | 23.9 | 25.6 | 27.2 | 28.8 | 30.4 | 32.0 |
| L | 120 | 3.0 | 4.7 | 6.4 | 8.1 | 9.8 | 11.6 | 13.3 | 15.0 | 16.7 | 18.4 | 20.1 | 21.8 | 23.5 | 25.3 | 27.0 | 28.7 | 30.4 | 32.1 | 33.8 |

Pressure Loss



Water Penetration

AMCA defines the beginning point of water penetration as the free area velocity at the intersection of a simple linear regression of test data and the line of 0.01 ounces of water per square foot of free area and is measured through a $48" \times 48"$ louver during a 15 minute period. The AMCA water penetration test provides a method for comparing louver models and designs as to their efficiency in resisting the penetration of rainfall under specific lab conditions. All-Lite recommends that intake louvers are selected with a reasonable margin of safety below the beginning point of water penetration in order to avoid unwanted penetration during severe storm conditions.

Selection Criteria

Follow the steps listed below to calculate the louver size needed to satisfy the required air volume while minimizing the adverse effects of water penetration and pressure loss.

- Determine the Free Area Velocity (FAV) at the maximum allowable pressure loss using the *Pressure Loss* chart to the left. While job conditions vary, typically, the maximum allowable pressure loss should not exceed 0.15 in.wg., and the FAV for 0.15 in.wg. pressure loss is listed on the front page of this sheet.
- 2. <u>Intake Applications</u> If the FAV at the Beginning Point of Water Penetration (shown below) is less than the FAV from step 1, then use the FAV at the Beginning Point of Water Penetration in step 3, otherwise use the FAV from step 1.

Exhaust Applications Use the FAV from step 1 in step 3.


3. Calculate the total louver square footage required using the following equation.

| | cfm ÷ | | fpm = | ft ² |
|------------|-------|-----|---------|-------------------------|
| Required | | FAV | Require | d Louver (Free-Area) |
| Air Volume | | | | Size in ft ² |

4. Using the Free Area chart above, select a louver width and height that yields a free area ft² greater than or equal to the required louver size calculated in step 3.

Water Penetration

Beginning Point of Water Penetration = 679 fpm



Information is subject to change without notice or obligation.